

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1062:124 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Detection Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski *(585) 223-4060 Fax (585) 421-4263

DESIGN: Models DSMS-SAWH, DSMS-SATH, DSMS-SAWK, DSMS-SATK, DSMS-DAWK, and DSMS-DATK noncoded manual pull stations. Suitable for outdoor use when installed with Model DSMS-WBB back box. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 30 VDC

INSTALLATION: In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual pull stations for use with separately listed and compatible fire alarm control units.

XLf: 7150-1408:107

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**